



HYDRANTS

CLOW "MEDALLION" AMERICAN DARLING MODEL B-62B, KENNEDY GUARDIAN K81A MUELLER "CENTURION", "MODERN CENTURION" M&H VALVE CO. STYLE 129 WATEROUS PACER. (2) 2-1/2" AND (1) 4" NST OUTLETS (OPEN COUNTERCLOCKWISE). 1-1/4" PENTAGON OPERATING AND CAP NUTS. DRIP PLUGS, IF ANY, SHALL BE PLUGGED. HYDRANTS SHALL BE LOCATED AT P/L EXTENSION, AT END OF CURB RETURN, 3' MIN. FROM DRIVEWAYS OR AS SHOWN ON PLANS.

HYDRANT "T" TO DUCTILE IRON PIPE OR PVC C-900 FOR NEW DEVELOPMENT

CITY WATER SYSTEM:
RING TITE BY RING TITE BY FLANGE.
CALIFORNIA WATER SERVICE CO.:
GRIP TITE BY GRIP TITE BY FLANGE.

CONTACT RESPECTIVE WATER SYSTEM REGARDING CONNECTION TO PIPE BY OTHER MATERIAL.

GATE VALVES

CLOW "RESILIENT WEDGE"
MUELLER "RESILIENT SEAT"
AMERICAN DARLING
KENNEDY RESILIENT
WATEROUS SERIES 500

REV. NO.	REV. DATE	REV. BY	FIRE HYDRANT	REVISION APPROVED BY CITY ENGINEER	
3	6/1/2000	HLE/RH		Finbar J. O'Regan	
DIGITIZED	7/1/90			DATE: 01/09/02	
DWG. BY	RC	SCALE	CITY OF STOCKTON DEPARTMENT OF PUBLIC WORKS	SUPERCEDES DWG. DATED	DRAWING NO.
CK. BY		NONE		10/7/93	101