



NOTES:

1. VALVE BOX AND LID SHALL BE CHRISTY NO. G5 OR EQUAL.
2. ALL LIDS SHALL HAVE MACHINED SEATING SURFACES.
3. EXTENSIONS SHALL BE C900 PVC WATER PIPE OR SDR 35 PVC SEWER PIPE. EXTENSIONS SHALL BE ONE CONTINUOUS PIECE.
4. FOR BLOWOFF INSTALLATION, REFER TO DRAWING NO. 98.
5. CONCRETE COLLAR NOT REQUIRED WHEN VALVE BOX IS LOCATED IN CONCRETE SIDEWALK AREA.

REV. NO.	REV. DATE	REV. BY	VALVE BOX DETAILS	REVISION APPROVED BY CITY ENGINEER	
5	6/1/2000	HLE/RH		<i>Finbar J. O'Regan</i>	
DIGITIZED	7/1/91		CITY OF STOCKTON		DATE: 01/09/02
DWG. BY	RC	SCALE	DEPARTMENT OF PUBLIC WORKS		SUPERCEDES
CK. BY		NONE			DWG. DATED 6/1/94
					DRAWING NO. 99